

## **DESIGN STATEMENT**

The grated pit is a standard open grate pit located within ROW or paving areas. The grate is selected depending on traffic conditions.

## APPLICABLE LOCATION

The grating pit should be used where advised by City Infrastructure Department of Merri-bek City Council.

#### **COUNCIL STANDARD DRAWING**

SD 125 Grated pit (600x900mm)

#### **CROSS REFERENCE DOCUMENT**

 Merri-bek City Council Standard Specifications: Sections 80 & 60. See Also: Urban Stormwater: Best Practice Environmental Management Guidelines; CSIRO Publishing.

#### STANDARD SPECIFICATION

Fixing: Hinged and bolt down

**Concrete strength:** 25 Mpa, unless stated otherwise. **Pits:** Shall be cast monolithically. Cement render shall only be used to repair defects. Pits over 2m in depth shall have SL72 reinforcing fabric placed centrally in walls.

Step irons shall be fitted to pits greater than 1m in depth (See SD 190). Minimum internal dimensions to be 600x600mm. Refer to Notes 1-3 as detailed in general note.

#### SUPPLIER

#### Supplier of grates:

- Access Covers P/L
- R&S Grating P/L
- SVC Products P/L
- Terra Firma Industries P/L
- Weldlok Grates P/L
- Gatic P/L or approved similar

#### MAINTENANCE

Street Cleansing Unit: Cleaning will be undertaken as per current schedule.


- **GENERAL NOTES**
- 1. For bluestone pitcher or asphalt right of ways, any exposed concrete shall be charcoal coloured.
- 2. Grate to be Access Covers P/L
  - R&S Grating P/L
  - SVC Products P/L
  - Terra Firma Industries P/L
  - Weldlok Grates P/L
  - Gatic P/L or approved similar
- 3. Grates and frame shall be galvanised steel with the grate hinged to its frame. The proposed grate and frame set must be approved by Council and to be bicycle safe prior to being used.



GENERAL

October 2022

# A140.07 Grated Pit (600x900)



FOR PIPES OVER 375mm Ø

SECTION A-A

